



## IRRIGATION INSTALLATION VERIFICATION FORM

RE: \_\_\_\_\_  
(Location address)

TO: **BUILDING OFFICIAL**

We, at \_\_\_\_\_, have installed and tested the irrigation system  
(IRRIGATION CONTRACTOR/BUSINESS NAME)

per the requirements set forth by the Texas Commission on Environmental Quality (TCEQ rule # 2007-027-344 CE)

We also affirm that:

1. The approved backflow device has been installed and tested and a copy of that report is provided to the Town of Sunnyvale prior to receiving the building final inspection,
2. The system is provided with a rain and freeze sensor.
3. The owner and/or representative has been provided:
  - a. Final walk-through of operation of system and location of isolation valve
  - b. Maintenance Check list with:
    - i. manufacturer's manual
    - ii. seasonal watering schedule
    - iii. list of components
    - iv. compliance statement
  - c. Permanent sticker attached to controller with warranty and contact information
  - d. As-built plans of system

\_\_\_\_\_  
(OWNER OR REPRESENTATIVE)

\_\_\_\_\_  
(DATE)

\_\_\_\_\_  
(APPLICANT'S SIGNATURE)

\_\_\_\_\_  
(DATE)

\_\_\_\_\_  
(IRRIGATOR'S NAME)

\_\_\_\_\_  
(IRRIGATOR LICENSE #)

PLEASE LEAVE THIS FORM AND TEST RESULT IN THE BUILDER'S PERMIT PACKET AT THE CONSTRUCTION SITE. SEE BACK FOR INSPECTION CHECK LIST.

(IF NOT NEW HOME CONSTRUCTION, INFO MUST BE RETURNED TO THE TOWN OF SUNNYVALE BUILDING INSPECTIONS DEPT)

## Sample Irrigation Inspection Check List\*

1. All valve boxes shall be accessible for inspection and repairs.
2. A. Verify isolation valve installed prior to backflow device.  
B. A “Y” strainer must be placed before the backflow device.  
C. There must be 4 inches of gravel at the bottom of the valve box and 3 inches of clearance from gravel to the backflow device.  
D. The backflow device must be accessible for testing.
3. Verify rain/freeze sensors are installed.
4. Spray heads shall be placed at least 4 inches from hard surfaces, (driveways, foundations, parking lots, etc.)
5. No spaces less than 48 inches wide may be irrigated with above ground spray heads.
6. The licensed Irrigator or the designated representative may be required to conduct an operational demonstration of the system in the presence of the Code Official.
7. System must not spray over impervious areas (pavement, walls, fences, decks, etc.)
8. Must provide copy of Irrigation Installation Verification Form.
9. Provide verification of backflow test.
10. Verify the (as-built) drawings/plans are on site.
11. A permanent sticker which contains the Irrigators company and warranty information shall be affixed to the controller.

\* This list is only general in nature and is not all inclusive of all code requirements. It is only intended to help the applicant prepare for final inspection on the installation of irrigation system.